



Insight  Onsite

Simplex, Inc. 5300 Rising Moon Road,
Springfield, IL 62711-6228
217-483-1600 (24hr.) 800-637-8603
217-483-1616 (Fax)
www.simplexdirect.com

SMARTPUMP Sample Specification

Engineer's specifications for a storage tank fill box with automatic overflow prevention and automatic fill shutoff.

1.0 Fuel Filling System

- 1.1 Provide a grade level fuel transfer pumping system with spill containment; overflow prevention and automatic fill shutoff. The SMARTPUMP shall be used for filling fuel oil storage tanks. The SMARTPUMP is for use with class II, flammable liquids, those having a flash point greater than 100 degrees F: fuel oil, diesel fuel, and kerosene.
- 1.2 The SMARTPUMP shall be supplied installed outdoors upon a concrete pad at a location as specified elsewhere.

The SMARTPUMP shall transfer fuel from a gravity tanker truck to storage tanks via the pump system on-board the unit, as described below. The SMARTPUMP shall permit full draining of the truck delivery hose upon completion of fuel delivery.

- 1.3 The SMARTPUMP shall include the following fittings and features:
- Full lockable weatherproof enclosure for SMARTPUMP with containment basin and hand pump.
 - External, stainless steel ground stud for attachment of delivery truck ground cable
 - 3" quick disconnect coupling for attachment of user's delivery hose
 - Inlet shutoff manual valve
 - 15 spill containment sump with drain to pump inlet
 - Outlet check valve
 - Outlet shutoff manual valve
 - 3" threaded fitting for attachment of outlet pipe to tank.
- 1.4 The SMARTPUMP shall include a motor driven high-capacity fuel transfer pump as follows:
- Pump: 300 GPM at 55 foot of head, 3600 RPM, cast iron, bronze fitted, carbon-ceramic / BUNA-N mechanical shaft seal
 - Motor: Totally enclosed, fan cooled, rigid base, 3600 RPM, 5 HP, (208/230/460) VAC, 3-phase
- 1.5 The SMARTPUMP shall include a PLC and 3" HMI controlled system with overflow alarm and shutoff system as described below. The system shall require an external source of AC power, 208/230/460, 3-phase.
- The control system shall include:
- TYPE 3R rainproof, lockable enclosure with hinged door
 - 4-20mA Level transmitter for installation in the storage tank
 - Leak sensor float switch for installation in the storage tank's interstitial space
 - Level display reading in Percent and Gallons
 - High visibility notification on HMI: 90% level
 - High visibility red alarm banner on HMI: 95% level
 - 90 dB audible alarm horn activated at 90%, 95%, and on storage tank leak
 - Control power ON/OFF switch
 - Fill Start/Stop controlled via HMI
 - Automatic pump stop at 90% level
 - Override circuit and 30 second timer to permit override of 90% shutoff to allow pump-out of delivery hose or spill containment. 95%, and leak lockout cannot be overridden.



Simplex, Inc. 5300 Rising Moon Road,
Springfield, IL 62711-6228
217-483-1600 (24hr.) 800-637-8603
217-483-1616 (Fax)
www.simplexdirect.com

- Leak sensor alarm circuit input
- Indicators for:
 - Power available
 - Tank leak
- Transfer pump motor starter with overload relay
- Control power transformer for 120 VAC operation of controls
- Control power fuses -Remote alarm contacts:
 - Tank High
 - Tank full
 - Leak
- Modbus via 485

- 1.6 The SMARTPUMP system shall be supplied with 1-year parts warranty.
- 1.7 The services of a factory-authorized or factory based, field service technician to provide start-up services, including inspection, calibration and first operation are available for the SMARTPUMP.
- 1.8 System shall be a Simplex SMARTPUMP, Model "SP-3" as described above. To be supplied by Simplex, Inc, 5300 Rising Moon Rd., Springfield, IL 62711. 217-483-1600.